

STATEMENT OF NEED
REPAIR BOILER WASTEWATER TREATMENT PLANT
375 CES SCOTT AIR FORCE BASE, ILLINOIS
12 APRIL 2023

1. Overview: The wastewater treatment plant serves all of Scott AFB to include Patriots landing, Lincoln's Landing and Shiloh East/West housing areas. In order to meet the parameters of the Illinois EPA Permit requirements, the sludge in the digesters must be kept within certain temperatures. The boiler in need of repairs circulates the waste sludge to maintain these temperatures. The contractor must demonstrate the ability to repair the boiler to within manufacturer specifications.
2. Summary of Services: Please see statement of work for requirements and quantities needed.
3. Period of Service: Due to the temperature sensitivity, it's desired this work be accomplished between 15 July 2023 and 15 August 2023, unless otherwise agreed upon by the government.
4. Unique Requirements: Access to SAFB is required by coordinating delivery, servicing and removal vehicles and drivers with the Civil Engineering (CE) Point of Contact (POC). Personnel requiring base access may be required to pass a preliminary background check and are subject to search upon arrival or departure from SAFB.
5. CE POC: Information will be provided at contract award.
6. Placement: Work shall be performed on site at the wastewater treatment plant boiler room; building 3296.